



Revista Internacional de Investigación e Innovación Tecnológica

Página principal: www.riit.com.mx

Permeability Fluid Test Prototype for Dental Sealers Using Digital Image Processing in LabVIEW

Prototipo de Prueba de Permeabilidad de Fluidos para Selladores Dentales Utilizando Procesamiento Digital de Imágenes en LabVIEW

Martínez-Montejano, R.C.^{a*}, Netro-Grimaldo, J.F.^a, Robles-Martínez, M.^b, Jaime-Rodríguez, J.J.^a, Gaitán-Fonseca, C.I.^c, Aguilera-Galaviz, L.A.^c, Pérez, E.^d.

^a Unidad Académica Multidisciplinaria Zona Media, Ingeniería Mecatrónica, Universidad Autónoma de San Luis Potosí, C. P. 79615. Rioverde, San Luis Potosí.

^b Doctorado Institucional en Ciencia e Ingeniería de Materiales, Universidad Autónoma de San Luis Potosí, C. P. 78000, San Luis Potosí, San Luis Potosí.

^c Unidad Académica de Odontología, Universidad Autónoma de Zacatecas, C. P. 98600, Guadalupe, Zacatecas.

^d Instituto de Física, Universidad Autónoma de San Luis Potosí, C. P. 78000, San Luis Potosí, San Luis Potosí.

*roberto.montejano@uaslp.mx

Technological Innovation: Fluids permeability test instrumentation using digital pictures. Industrial Implementation Area: Odontology

Received: June 12th, 2019

Accepted: October 20th, 2019

Resumen

Un tratamiento endodóntico debe de ser capaz de prevenir el crecimiento bacteriano y la filtración de fluidos. Para poder probar la efectividad de un sellador dental, este debe de pasar por una serie de pruebas, dentro de las cuales se encuentra el método de penetración de fluidos. Esta prueba demuestra la capacidad de sellado de un cemento dental. El objetivo de este artículo consiste en presentar el trabajo de construcción de un prototipo para esta prueba que midiera cuantitativamente la microfiltración basada en la prueba de Pashley. El prototipo consiste de un tanque de oxígeno conectado a un sistema de presión que va hacia una caja acondicionada. Dentro de la caja, se encuentra una cámara USB con luz LED, una entrada de la caja, tiene adherida una jeringa y en la salida de la caja se ubica un diente obturado con el sellador. Se introduce una burbuja de aire en el sistema mediante la jeringa y la cámara USB monitorea el desplazamiento de la burbuja y el cálculo de la microfiltración es hecho mediante procesamiento digital de

imágenes en LabVIEW. El prototipo fue probado con tres selladores dentales diferentes y se puede concluir que funciona correctamente para evaluar la microfiltración.

Palabras clave: LabVIEW, permeabilidad, procesamiento digital de imágenes, sellador endodóntico.

Abstract

An endodontic treatment must be capable of preventing bacterial growth and fluid filtration. To prove the effectiveness of a dental sealer, it must pass through several tests, among them the fluid penetration method. This test shows the hermetic capability of dental cement. This paper presents the construction of a prototype for such test to measure the quantitative evaluation of microleakage based on Pashley test. The system consists of an oxygen cylinder connected to a pressurized system and linked to a conditioning box. Inside the box, there is a USB camera with LED light, one entry of the box holds attachments for a syringe and a tooth with cement, is placed at the box output. A bubble air is introduced to the system by the syringe and the USB camera records the bubble displacement, and the microleakage calculation is made using digital image processing on LabVIEW. The prototype is tested with three different types of dental cement and can be concluded its correct performance for evaluating microleakage.

Key Words: digital image processing, endodontic sealer, LabVIEW, permeability.

1. Introduction

The dental sealer aim is to prevent a phenomenon known as microfiltration, which may be present between intraradicular dentine and cement. Avoiding this problem, the interior of the root canal must not show bacterial growth at the Surface (1,2). An ideal dental sealer must accomplish the following requirements (3,5):

- Non-irritant to the tooth and periapical tissues
- Insoluble in tissue fluids
- Non-staining the tooth
- Dimensionally stable
- Non-resorbable
- Radiopaque
- Good mixing consistency
- Biocompatibility

To exhibit effectiveness, a dental sealer must pass through several tests as push out resistant dislodgment, hydrophobicity properties measurement, spectrophotometry analysis, rheological measurements, radiopacity, etc.

Methodologies *in vitro* are used to estimate sealing capacity, by measuring microleakage that allows the tracer agent to penetrate the filled canal. The commonly used tracers are dyes, radioisotopes, bacteria, and their products. Other methodologies, such as fluid filtration and dye extraction methods have also been used, their advantage is the high reproducibility (6).

Several filtration methodologies reported in the literature applied to colorants, fluids, and gas, have been used to evaluate the sealer capability of different types of cement and endodontic materials. According to these

methodologies, the sealer hermetic importance at the obturation favors the periapical chronic damage obturation. Besides, the principal conduit different ramifications can exhibit bacterial presence that induces necrosis and pulpal infections, resulting in periodontal problems. This remarks the sealer penetration value on non-visible spaces (7, 9).

Fundamental physical laws give direction to the fluid penetration model, necessities for endodontic microfiltration studies, to develop experimental methods and understand the obtained results. Microfiltration is the space created between the surfaces at the root canal interior, it is a complex process that can be experimentally reproduced by fluid model penetration. Nevertheless, each experimental technique presents advantages and disadvantages (10). The model was proposed by Pashley (11), which involves the bubble air movement through a capillary tube filled with liquid. This method presents many advantages in comparison with other methods as dye penetration, as the samples are not destroyed, allowing apical and coronal sealing being assessed after a long period. The results are recorded automatically, avoiding operator errors and providing quantitative measurements, the results are precise, and it is more sensitive than dye penetration method (12).

The microfiltration can be measured by the fluid filtration method, which is more according to the clinical conditions. Despite there is no standardization, a study reported in (13) suggests better values for pressure and time for the experimental setup. The system requires of a certainty pressure, generated by a nitrogen or oxygen tank, and the optimal pressure was reported as 15 psi, due to clinical conditions and is ideal for a high sensibility system. The same study reports also that 1-hour measurement time should be adequate even when other authors present

times from 50 seconds to 3 hours because the uncertain between the clinical conditions and experimental conditions.

The LabVIEW software can be used for several purposes such as computations, instrumentation, machine vision, etc. The image processing using block representation is a simple method, IMAQ Vision includes edge detection, object tracking, histogram, pattern matching, etc. Then, the increased application of LabVIEW virtual instruments is due their flexibility and the ability to satisfy specific user requirements combined with construction simplicity (15).

This paper presents the development of experimentation and automatization of permeability fluid technique. The following objectives are desirables:

- To generate a 15 Psi of pressure in a closed system having the pressure source in one extreme and the obturated tooth in the other.
- To introduce the air bubble to the system and record it along its way.
- To measure the bubble's total path length through digital imagen processing
- To develop an easy user interface capable to save the images obtained during the process, establish the test time, and automatically returns the distance traveled by the air bubble.

2. Materials and equipment

Materials: venoclysis equipment, syringe, obturated dental piece, hose couplers, electrical transformer, diodes, resistors, capacitors, voltage regulator, LED's.

Equipment: USB camera Logitech C920 Full HD 1920x1080, Laptop Dell Inspiron 15 5000 series, LabVIEW 2014 with IMAQ Vision toolbox, Ecko cooking pot of 5L,

Presto analog manometer.

3. Methodology

The fluid penetration model prototype developed in this work consisting on a pressure system built with a cooking pot, a source to reach the pressure as nitrogen tank

or an air compressor, generating 15 psi of pressure, to a liquid with a contrast medium. The equipment has three main parts: the cooking pot, a conditioned USB camera for image processing linked to a computer with LabVIEW and a sealed tooth connected through a capillary tube (with 4 mm of diameter) to the system, as shown in the CAD design in Figure 1.




Figure 1. CAD design of the experimental setup.

The cooking pot has a manometer installed to visualize the correct pressure at the system. The second box in Figure 1, represents the voltage source for the LED light, it is consisting on a transformer, a diode bridge, a capacitor to reduce the voltage ripple and a voltage regulator to provide 5V and 1.5A on DC voltage.

An air bubble is introduced to the system at 15 psi using a syringe, and the USB camera monitored its position. If the bubble moves, it indicates tooth filtration, otherwise, if the bubble is almost static, the dental sealer will be clinically apt for use.

To avoid perturbation of other light

intensities, the USB camera must be conditioned, so then, it is implementing a sealed box with LED light and a capillary tube, as shown in Figure 2.



Figure 2. USB camera conditioning.

The digital image processing is performed on LabVIEW and IMAQ vision toolbox. IMAQ vision toolbox presents a complete set of digital image processing and acquisition functions that improve the efficiency of the

projects and reduce the programming effort. The main objective is to measure the bubble displacement in the system, for this purpose the methodology described on Figure 3 is implemented.




Figure 3. Program methodology.

As we can see on Figure 3, firstly, a reference image at a grayscale is taken with the system at conditions stated above without an air bubble. Then, the second image in grayscale capture the air bubble presence when this it is injected to the system, and the program automatically performs the subtraction between the reference image and the second one to isolate the region of interest. Next, the third image at grayscale is taken 60 minutes later and it is subtracting with the reference image. Finally, a subtraction between both regions of interest is performed and the result is measured in pixels per centimeter using the VI IMAQ clamp horizontal block. The whole experiment consists of taking three images

and making the digital image processing to obtain the microfiltration. The max range of measure depends on the image covered by the camera (approximately 5 cm).

3.1 Program development

The program developed in this paper was performed following the methodology stated previously with the main objective of making it friendly for the user. It is split into two user interfaces, the first interface obtains the regions of interest for the air bubble at the beginning of the experiment and at the end of the experiment, the second interface

computes the longitude path achieved by the air bubble. The user interface I is as shown in

Figure 4.




Figure 4. User interface I.

The interface displays the real-time camera, the reference image (image A), the picture with a bubble at the beginning of the experiment (image B), the image at the end of the experiment (image C), and the subtraction of these pictures. The final user must choose the camera port, set the experiment time, set the folder address where the pictures will be saved, give a click on the image without bubble and press the begin button and the program automatically performs the process described above.

The block diagram of the interface I is displayed in Figure 5, where the main

processes are enclosed on boxes. The black box shows the real-time camera initialization, the red box depicts the process for transforming the image in grayscale, this block is repeated inside the other boxes (three times), because each image taken, is transformed at grayscale. The yellow box exhibits the process for picture B and the subtraction with the image A to obtain the region of interest. Finally, the blue box presents the subtraction between image A and C, and picture B and C. The whole results are saved in a specified route established by the user.




Figure 5. Interface I block diagram.

For the measurements process, a second interface was developed, and this user interface is shown in Figure 6. The last image of the first interface is exported by clicking on the folder icon, where the user specifies the route. The customer has the options to zoom

the picture, handle it, and enclose the region of interest in a box. The system counts the pixel per dots containing at the region of interest and transforms this quantity on centimeters, this value represents the distance achieved by the air bubble.




Figure 6. Interface II frontal panel.

LED's, and the computer with the interface developed in LabVIEW.



Figure 8. Experimental setup.

Then, figure 9 shows the results obtained with the interface I, where clause a) depicts the reference image without air bubble. Clause b) shows the figure obtained where the air bubble is into the system, and the subtract between clause a) and clause b) is shown in

clause d). Then, clause c) displays the air bubble captured after the time established by the user (60 minutes) and clause e) presents the subtract between clause c) and clause a). Finally, clause f) shows the subtract between clause d) and clause e).




Figure 9. Interface I results.

The image at clause f) in Figure 9, is exported to the second interface to compute the air bubble path length. Figure 10 shows the result obtained, where the region of interest is enclosed in a box and automatically the program computes the distance on centimeters. For this case was of 0.05 cm. The result is expressed in $\mu\text{L}/\text{min}/\text{cmH}_2\text{O}$, because the results depend directly from the pressure (15 psi which is equal to $1054.4 \text{ cmH}_2\text{O}$) and the time (60 minutes), so it is necessary to be included. The volume is computed used the distance traveled by the air bubble (0.05 cm) and the capillary tube area (1.25×10^{-5}). With this data, the sample bubble movement was calculated as

$9.9 \times 10^{-5} \mu\text{L}/\text{min}/\text{cmH}_2\text{O}$, which is consistent with the values presented in (13).

Different dental sealers were proved for verified the prototype performance, one commercial (AH Plus) and two experimental developments. One of these experimental developments were presented in (14), and the other one is in a patent process for researcher of the Physics Institute of UASLP. Each test was made by triplicate for giving ensure the results, obtaining the average data described in table 1. The whole values obtained are in the range of $3.8 \times 10^{-5} \mu\text{L}/\text{min}/\text{cmH}_2\text{O}$ and $43 \times 10^{-5} \mu\text{L}/\text{min}/\text{cmH}_2\text{O}$ presented in (13).

Table 1. Average results in three different dental sealers.

Dental sealer	Distance (cm)	Result in $\mu\text{L}/\text{min}/\text{cmH}_2\text{O}$
Commercial	0.05	9.9×10^{-5}
Dental sealer developed in (14)	0.06	11.9×10^{-5}
New experimental dental sealer	0.04	7.9×10^{-5}




Figure 10. Interface II results.

4.1 Discussion

The prototype developed presents similarities, advantages, and disadvantages against others system based in Pashley test presented in previous works. The similarities are the pressure, closed system, controlled source for pressure, and air bubble injection. In (16), the authors use a digital SLR camera with AutoCAD as interface; the experiment is mounted on a dark surface with a rule to measure the bubble displacement. In (1), a graduated pipette is used to visualize the bubble movement, and no camera is used. On the other hand, in (14) presence sensors are used as a barrier for determining if there exists microfiltration.

The advantages are:

- The user can establish the pressure and the time of the test. There is no standardization of these values in the literature, however the values used in this paper are according to reference (13).
- A high definition USB camera was used for recording the bubble displacement, this camera is low in price than an SLR digital camera. The minimum resolution achieved by the camera is 1.79 mm (obtained by divide each centimeter by the constant of 560 pixels) and the maximum value is 5 cm.
- The automatized process in LabVIEW for taking images, processing them and the test duration.
- The captured images are saved on a specified route established by the user.
- It is possible to calculate the bubble displacement using digital image processing and automatically return the distance.

The observed disadvantages are:

- The using of two interfaces for achieving the whole process, and it complicates the easy use of the test.
- The need to use a contrast medium to visualize properly the air bubble.
- The tooth fixation in the system is complicated, it is necessary to use better materials to attach it.
- The camera resolution is low (560 pixel's per centimeter), with a more powerful camera the results can be improved.

5. Conclusions

This paper presents the developing and automatization for permeability fluid method to prove microfiltration on dental sealers.

The experimental setup consists of a cooking pot linked to a nitrogen tank or air compressor to generate 15 psi of pressure with a liquid (water) with a contrast medium (white colorant). At the cooking pot output a box, conditioning with white LED light and a camera are connected and then, at the box output, an obtured tooth with a commercial sealer is fixed. The air bubble is injected into a capillary tube through a syringe. The program has two interfaces developed in LabVIEW, the first one, captures the images on grayscale, isolates the region of interest (air bubble) and perform the subtract between the image with the air bubble at the beginning of the experiment and the image with the air bubble at the end of the experiment (60 minutes later).

The second interface uses the image obtained from subtracting between air bubbles, and the user encloses this result in a box. The box computes the pixels per dots quantity of the

figure and changes this value to centimeters.

Experimental results were carried out with two experimental sealers and a commercial sealer on an obturated tooth and the distance measured in a triplicated experiment, and results are consisting between them. It can be concluding that the experimental setup works properly.

As future work, it will perform more test with different dental sealers and improve the user interface to make it friendlier.

6. Acknowledgements

This work was supported by Research Support Found (FAI) of UASLP and UAZ-PTC-210 PRODEP.

7. References

1. Mousavi, S.A., Khademi, A., Soltani, P., Shalnasari S., Poorghorban M. (2018). Comparison of a sealing ability of ProRoot mineal trioxide aggregate, biodentine and ortho mineral trioxide aggregate for canal obturation by the fluid infiltration technique. *Dent. Res. J (Isfahan)*. 5, 307-312, doi: 10.4103/1735-3327.240470.
2. Shetty, S., Hiremath, G., Yeli, M. (2017). A comparative evaluation of sealing ability of four root end filling materials using fluid filtration method: An in vitro study. *J. Conserve Dent*. 5, 307-310, doi: 10.4103/JCD.JCD_122_17.
3. Chong, B.S. (2004). Managing endodontic failure in practice. *Quintessence Publishing Co.* 123-47, doi: 10.1038/sj.bdj.4811836.
4. Enkel, B., Dupas, C., Armengol, V., Akpe, J., Bosco, J., Daculsi, G., Jean, A., Laboux, O., LeGeros, R.Z., Weiss, P. (2008). Bioactive materials in endodontics. *Expert Rev. Med. Dev.* 4, 475-94, doi: 10.1586/17434440.5.4.475.
5. Lee, Y.L., Lee, B.S., Lin, F.H., Yun, A., Lan, W.H., Lin, C.P. (2004). Effects of physiological environments on the hydration behavior. *Biomaterials*. 5, 787-93, doi: 10.1016/S0142-9612(03)00591-X.
6. Pommel, L., About, I., Pahsley, D., Camps, J. (2003). Apical leakage of four endodontic sealers. *J. Endodontics*. 29, 208-210.
7. Jafari, F., Jafari, S. (2017). Importance and methodologies of endodontic microleakage studies: A systematic review. *J. Clin. Exp. Dent*. 6, 812-819, doi: 10.4317/jced.53604.
8. Savadhouhi, S.T., Bakhtiar, H., Ardestani, S.E. (2016). In vitro and ex vivo microbial leakage assessment in endodontics: A literature review. *J. Int. Soc. Prey Community Det*. 6, 509-516, doi: 10.4103/2231-0762.195516.
9. Generali, L., Prati, C., Pirani, C., Cavani, F., Gatto, M.R., Gandolfi, M.G. (2017). Double dye technique and fluid filtration test to evaluate early sealing ability of an endodontic sealer. *Clin. Oral Investigation*. 4, 1267-1276, doi: 10.1007/s00784-016-1878-0.
10. Romieu, O.J., Zimnyi, L., Warsynski, P., Levallois, B., Cuisinier, F.J., de Periere, D.D., Jacquot, B. (2010). Modeling colorant leakage techniques: application to endodontics. *Dent. Mater*. 9, 881-900, doi: 10.1016/j.dental.2010.05.003.
11. Brenes-Valverde, K., Cornejo-Rodríguez, E., Vega-Baudruit, J., Montero-Aguilar, J., Chavarría-Bolanos, D. (2018). Evaluation of microleakage

- by gas permeability and marginal adaptation of MTA and Biodentine apical plugs: in vitro study. *Odytos-International Journal of Dental Science*. 20, 57-67, doi: 10.15517/ijds.v0i0.28952.
12. Moreira-Veríssimo, D., Sampaio, M. (2006). Methodologies for assessment of apical and coronal leakage of endodontic filling materials: a critical review. *Journal of Oral Science*. 48, 3, 93-98.
13. Pommel, L., Camps, J. (2001). Effects of pressure and measurement time on the fluid filtration method in endodontics. *Journal of endodontics*. 4(27), 256-258, doi: 10.1097/00004770-200104000-00003.
14. Patino-Herrera, R., Morales-Rueda, J.A., Gaitan-Fonseca, C., Cuisinier, F.J., Perez, E. (2016). Intrarradicular dentine salinization by a new silicon-based endodontic sealer. *International Journal of Adhesion and Adhesives*. 69, 115-124, doi: 10.1016/j.ijadhadh.2016.03.013.
15. Ramos, R., Zlatev, R., Valdez, B., Stoytcheva, M., Carrillo, M., García, J.F. (2013). LabVIEW 2010 computer vision platform based virtual instrument and its application for pitting corrosion study. *Journal of Analytical Methods in Chemistry*. 1-8, doi: 10.1155/2013/193230.
16. Sheik, A., Hedge, V., Shanmugasundaram, S., Dixit, V. (2017). A novel approach to construction and working fluid filtration model: An experimental study. *Journal of Scientific and Innovative Research*. 2, 55-58.